WEIL- McLAIN

EASY-LOOP BOOKLET

FOR ESTIMATING
RESIDENTIAL HYDRONIC SYSTEMS

FEATURES:

- HEAT LOSS CALCULATION
- BOILER & BASEBOARD SELECTION
- PIPE SIZING
- JOB QUOTATION

This Manual provides simplified procedures for designing an Easy-Loop Hydronic System using Weil-McLain Boilers, Convector Baseboard and Series-Loop piping.

In this system, 3/4" Convector Baseboard serves as a part of the system piping. This series loop design offers all the unequalled advantages of modern forced hot water heating and may be used in all types of residential construction.

By following the simplified design and estimating procedures in this Manual, the hydronic heating contractor will quickly be able to provide price estimates for more jobs with less effort. Once a job has been sold, a complete I=B=R calculation and piping layout should be made to accurately locate the necessary baseboard panels in each room; thus little time need be expended upon any job except those that are sold.



FEATURES OF AN EASY-LOOP SYSTEM

Installation time and material costs are substantially reduced with an Easy-Loop system since the convector baseboard eliminates a major portion of the piping. Actual tests have proven that installation time can be reduced over 50% and piping material costs reduced a like amount by eliminating pipe, pipe fittings, radiator union ells, radiator valves, etc. Listed below are other major features and advantages of a Weil-McLain Easy-Loop System.

- 1. The appreciably lower installed cost assures the availability of a quality hydronic heating system for more home owners.
- 2. Adaptable to all types of residential construction

including ranch, two story, basementless, split level homes and multiple apartment units.

- 3. Zoning can be provided at low additional cost through the use of more than one loop, and with zone valves or circulators.
- 4. Comfort conditions in the home are equivalent to a system using a conventional one-pipe system.
- 5. Can be installed in basementless and slab type ranch homes at costs which are comparable to a warm air system.

The following simple steps provide an accurate "shortcut" method for designing an Easy-Loop System.

ESTIMATE TOTAL HEAT LOSS

Select from the Construction Design Table, those features that best identify the construction for the area which is to be heated. Choose the appropriate heat loss according to square feet of floor area and record this heat loss in the proper line below. Repeat this procedure for other areas. Determine design temperature difference for the locale and the corresponding correction factor on Page 4. Then multiply

total heat loss calculated for each area by the correction factor to obtain the adjusted heat loss on which to base boiler selection.

NOTE: Do not add in heat losses for basements which are not to be heated. Ignore crawl spaces which are open to basement areas. Make deduction from first floor heat loss for two story structures.

LEVEL	CONSTRUCTION NO.	AREA SQ. FT.	HEAT LOSS AT 70°F. DESIGN TEMP. DIFF.	CORRECTION FACTOR AT°F.	ADJUSTED HEAT LOSS (TO NEAREST TEN)
	- Company of the Comp		Annual Control of Cont	Χ	gypna ymae
FIRST LEVEL			The second secon	3 X	
SECOND LEVEL				X	6-000 Decreption of the control of t
MID-LEVEL				Χ	Angulation and the first and t
BASEMENT				Χ	
FLOOR				Χ	
			TOTAL ADJ	JSTED HEAT LOSS	AGE STORY

EXAMPLE:

26' x 50' Ranch type house, single story (8 ft. ceiling) with basement, 1300 sq. ft. floor area.

Construction: Double glass, weatherstripped, 2" wall insulation, 3" ceiling insulation.

Design temperature difference: 80°F.

Owners wish to heat first floor and basement.

Owners wish to zone into living, sleeping, and basement areas.

By following the instructions in Step 1 and using this example, the total adjusted heat loss is calculated as shown below.

CONSTRUCTION	AREA SQ. FT.	HEAT LOSS AT 70°F. DESIGN TEMP. DIFF.	CORRECTION FACTOR AT 80°F.	ADJUSTED HEAT LOSS (TO NEAREST TEN)
INV.			1 15	_ 42,940
5	1300	37,340	X	
			X	Abuse and a second
			Χ	
22	1300	13,340	X	= 15,340
			Χ	58,280
	NO. 5	5 1300	CONSTRUCTION NO. AREA SQ. FT. AT 70°F. DESIGN TEMP. DIFF. 5 1300 37,340 22 1300 13,340	CONSTRUCTION NO. AREA SQ. FT. AT 70°F. DESIGN TEMP. DIFF. FACTOR AT 80°F. 5 1300 37,340 X 1.15 X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X X

CONSTRUCTION DESIGN TABLE

(8 FT. CEILING HEIGHT)

	(O) 1. CERTINO HEROITI	
CONSTRUCTION NO. 1 Single glass, weatherstripped 1" Wall Insulation 2" Ceiling Insulation	CONSTRUCTION NO. 2 Double glass, weatherstripped 1" Wall Insulation 2" Ceiling Insulation	CONSTRUCTION NO. 3 Single glass, weatherstripped 1" Wall Insulation 3" Ceiling Insulation
CONSTRUCTION NO. 4 Double glass, weatherstripped 1" Wall Insulation 3" Ceiling Insulation	CONSTRUCTION NO. 5 Double glass, weatherstripped 2" Wall Insulation 3" Ceiling Insulation	CONSTRUCTION NO. 6 Double glass, weatherstripped 3" Wall Insulation 3" Ceiling Insulation
CONSTRUCTION NO. 7 Double glass, weatherstripped 3° Wall Insulation 6" Ceiling Insulation 2" Floor Insulation	CONSTRUCTION NO. 8 Double glass, weatherstripped 3" Wall Insulation 6" Ceiling Insulation Full Basement or Crawl Space	CONSTRUCTION NO. 9 Double glass, weatherstripped 3" Wall Insulation 9" Ceiling Insulation Full Basement or Crawl Space
CONSTRUCTION NO. 10 Double glass, weatherstripped 3" Wall Insulation 12" Ceiling Insulation Full Basement or Crawl Space	CONSTRUCTION NO. 11 Double glass, weatherstripped 6" Wall Insulation 6" Ceiling Insulation Full Basement or Crawl Space	CONSTRUCTION NO.12 Double glass, weatherstripped 6" Wall Insulation 9" Ceiling Insulation Full Basement or Crawl Space
CONSTRUCTION NO. 13 Double glass, weatherstripped 6" Wall Insulation 12" Ceiling Insulation Full Basement or Crawl Space	CONSTRUCTION NO. 14 4" Brick, 4" Light Weight Block Furred, Lath and Plaster 2" Ceiling Insulation Single Glass, Weatherstripped	CONSTRUCTION NO. 15 4" Brick, 4" Light Weight Block Furred, Lath and Plaster 2" Ceiling Insulation Double Glass, Weatherstripped
CONSTRUCTION NO. 16 4" Brick, 4" Light Weight Block Furred, Lath and Plaster 3" Ceiling Insulation Single Glass, Weatherstripped	CONSTRUCTION NO. 17 4" Brick, 4" Light Weight Block Furred, Lath and Plaster 3" Ceiling Insulation Double Glass, Weatherstripped	CONSTRUCTION NO. 18 8" Brick, Furred, Lath and Plaster 2" Ceiling Insulation Single Glass, Weatherstripped
CONSTRUCTION NO. 19 8" Brick, Furred, Lath and Plaster 2" Ceiling Insulation Double Glass, Weatherstripped	CONSTRUCTION NO. 20 8" Brick, Furred, Lath and Plaster 3" Ceiling Insulation Single Glass, Weatherstripped	CONSTRUCTION NO. 21 8" Brick, Furred, Lath and Plaster 3" Ceiling Insulation Double Glass, Weatherstripped
CONSTRUCTION NO. 22 Concrete or Block Walls 8' high — 6½' below grade. Stray heat from boiler and piping included — OR — unheated crawl spaces.	CONSTRUCTION NO. 23 4" Concrete Slab with 1" Perimeter Insulation	

HEAT LOSS TABLE* (Continued on Page 4) CALCULATED AT 70°F. DESIGN TEMPERATURE DIFFERENCE

Floor Area					CONST	RUCTION	DESIGN				
Sq. Ft.	No. 1	No. 2	No. 3	No. 4	No. 5	No. 6	No. 7	No. 8	No. 9	No. 10	No. 11
500	28,750	23,900	27,350	22,510	18,075	16,860	17,910	16,160	15,460	15,110	15,360
600	32,300	27,030	30,620	25,350	20,520	19,200	20,460	18,360	17,520	17,100	17,490
700	35,860	30,150	33,900	28,190	22,970	21,540	23,010	20,560	19,580	19,090	19,610
800	39,840	33,590	37,600	31,350	25,640	24,080	25,760	22,960	21,840	21,280	21,920
900	43,340	36,680	40,820	34,160	28,050	26,380	28,270	25,120	23,860	23,230	24,010
1000	46,890	39,800	44,090	37,000	30,500	28,720	30,820	27,320	25,920	25,220	26,140
1100	50,450	42,920	47,370	39,840	32,940	31,060	33,370	29,520	27,980	27,210	28,270
1200	54,000	46,040	50,640	42,680	35,390	33,400	35,920	31,720	30,040	29,200	30,400
1300	56,640	48,470	53,000	44,830	37,340	35,300	38,030	33,480	31,660	30,750	32,120
1400	60,200	51,590	56,280	47,670	39,790	37,640	40,580	35,680	33,720	32,740	34,240
1500	62,830	54,030	58,630	49,830	41,740	39,540	42,690	37,440	35,340	34,290	35,970
1600	65,530	56,490	61,050	52,010	43,730	41,480	44,840	39,240	37,000	35,880	37,730
1700	68,590	59,250	63,830	54,490	45,910	43,570	47,140	41,190	38,810	37,620	39,630
1800	71,720	62,040	66,680	57,000	48,130	45,710	49,490	43,190	40,670	38,410	37,950
1900	73,930	64,150	68,600	58,830	49,860	47,410	51,400	44,750	42,090	40,760	43,120
2000	77,050	66,940	71,450	61,340	52,080	49,550	53,750	46,750	43,950	42,550	45,070
· ·	18%	21%	12%	1 4%	17%	18%	12%	14%	9%	6%	14%

^{*} Based upon I-B-R calculations where ceiling height is 8 ft. and where total window and door areas do not exceed 20 percent of the GROSS wall area. For 9 ft. ceiling height add 11 percent to heat loss; for 10 ft. ceiling height, add 22 percent. For lower levels ONE HALF or LESS below grade level, use FIRST FLOOR heat loss.
† Deduct these percentages from FIRST FLOOR heat loss for two-story structures.

HEAT LOSS TABLE*

CALCULATED AT 70°F. DESIGN TEMPERATURE DIFFERENCE

			PH 2.45P APA 100 APA									
Floor					COP	USTRUCTIO	ON DESIG	3N				
Area	No. 12	No. 13	No. 14	No. 15	No. 16	No. 17	No. 18	No. 19	No. 20	No. 21	No. 22	No. 23
Sq. Ft.				25,520	28,960	24,120	32,780	27,940	31,380	26,540	5,130	4,350
500	14,660	14,310	30,360		32,380	27,105	36,690	31,420	35,010	29,740	6,150	4,725
600	16,650	16,230	34,060	28,790 32,050	35,780	30,090	40,600	34,890	38,650	32,930	7,180	5,220
700	18,630	18,140	37,760	35,670	39,680	33,430	45,040	38,790	42,800	36,550	8,210	5,600
800	20,800	20,240	41,920	38,910	43,040	36,390	48,890	42,240	46,370	39,720	9,230	5,980
900	22,750	22,120	45,560	42,170	46,460	39,370	52,810	45,720	50,010	42,920	10,250	6,370
1000	24,740	24,040	49,260	45,430	49,880	42,350	56,720	49,190	53,640	46,110	11,300	6,750
1100	26,730	25,960	52,960	48,690	53,300	45,330	60,630	52,670	57,270	49,310	12,330	7,150
1200	28,720	27,880	56,660	51,200	55,720	47,560	63,450	55,290	59,810	51,650	13,340	7,330
1300	30,300	29,390	63,060	54,460	59,140	50,540	67,360	58,760	63,440	54,840	14,370	7,720
1400	32,280	31,300	65,770	56,970	1 '	52,770	70,180	61,380	65,980	57,180	15,400	7,920
1500	33,870	32,820	68,540	59,500	64,060	55,020	73,050	64,020	68,570	59,540	16,420	8,11
1600	35,490	34,370	71,710	62,370		57,610	76,390	67,050	71,630	62,290	17,440	8,40
1700	37,250	37,800	74,950	65,270	1	60,230	79,780	70,110	74,740	65,070	1	8,69
1800	39,060	39,130	77,190		1		82,080	72,304	76,760	66,990	1	9,27
1900	40,460	40,870	80,420	70,310	1 '	1	85,470	75,360	79,870	69,760	20,600	9,56
2000	42,270	+	-		12%	13%	16%	18%	11%	12%		_
and the second	9%	6%	17%	20%	1 4./0	1 10/0		1 3				week and the second

^{*}Based upon I-B-R calculations where ceiling height is 8 ft and where total window and door areas do not exceed 20 percent of the GROSS wall area. For 9 ft ceiling height add 11 percent to heat loss; for 10 ft. ceiling height, add 22 percent. For lower levels ONE HALF or LESS below grade level, use FIRST FLOOR heat loss.

**Use for basement heat losses WITHOUT fully exposed walls and for floor losses over closed unheated crawl spaces. For basements with fully exposed walls, use FIRST FLOOR heat loss.

***Use for grade level slab construction.

†Deduct these percentages from first floor heat loss for two-story structures.

CORRECTION FACTORS

FOR OTHER THAN 70°F DESIGN TEMPERATURE DIFFERENCE

DESIGN TEMPERATURE DIFFERENCE 25°F 30°F 35°F 40°F 45°F 50°F 55°F 60°F 65°F FACTOR 0.35 0.42 0.50 0.57 0.64 0.71 0.78 0.85 0.92												i .
TEMPERATURE DIFFERENCE 25°F 30°F 35°F 40°F 45°F 50°F 55°F 60°F 65°F									-			į.
TEMPERATURE DIFFERENCE 25°F 30°F 35°F 40°F 45°F 50°F 55°F 60°F 65°F								1 1	1	1		é
TEMPERATURE DIFFERENCE 25°F 30°F 35°F 40°F 45°F 50°F 55°F 60°F 65°F					1	1	1	1	1	i		ŝ
TEMPERATURE DIFFERENCE 25°F 30°F 35°F 40°F 45°F 50°F 55°F 60°F 65°F	7	1	1	2	1			1	1	ı		1
0.50 0.57 0.64 0.71 0.78 0.85 0.92	CONTRACTOR OF THE PERSON NAMED IN CONTRA	TEMPERATURE	25°F	30°F	35°F	40°F	45°F	50°F	55°F	60°F	65°F	And in Section Control of the Contro
	The state of the s	FACTOR	0.35	0.42	0.50	0.57	0.64	0.71	0.78	0.85	0.92	gain a constant and a

				y					
DESIGN TEMPERATURE DIFFERENCE	75°F	80°F	85°F	90°F	95°F	100°F	105°F	110°F	15°F
FACTOR	1.07	1.15	1.20	1.29	1.36	1.43	1.50	1.57	1.64

NOTE: Conversion Factor for "In Between" temperatures can be determined by interpolation between the closest tabulated values. EXAMPLE: The outdoor design temperature in Cincinnati, Ohio is 1.° F. Indoor minus outdoor temperature equals 58°. F. Interpolated factor equals 0.82 (Rounded).

STEP 2. SELECT BOILER AND BASEBOARD

The BOILER AND BASEBOARD SELECTION TABLE below will provide for the selection of a gas or oil boiler (based upon I=B=R Net Ratings). This same table also provides for the selection of Weil-McLain convector baseboard and is based upon I=B=R Ratings using 200°F, average water temperatures (see note at bottom of page).

(a)	Opposite NEAREST total heat loss, select gas or oil boiler:
	Record Boiler Selection Here
(b)	Follow line opposite NEAREST total heat loss to select total lineal feet of convector baseboard: Record Convector Baseboard Selection Here:
(c)	Follow line opposite NEAREST total heat loss to select

total number of end caps or end boxes:

Record Number Here:

EXAMPLE:

Continuing with previous example and following the above instructions for STEP2, select a gas-fired boiler, baseboard and end caps for the total heating load of 58,280 BTUH from BOILER AND BASEBOARD SELECTION TABLE:

(a) Opposite NEAREST total heat loss of 58,280 BTUH, select VHE-4 gas fired boiler. Record Boiler Selection Here: VHE-4

(b) Follow line opposite NEAREST total heating load of $58,280\,BTUH$ and select total lineal feet of 3/4 " Therma Trim Baseboard:

Record Baseboard Selection Here:

(c) Follow line opposite NEAREST total heating load of 58,280 BTUH and select total number of end caps:

Record Number Here:

BOILER AND BASEBOARD SELECTION TABLE

Heat Loss Total BTUH			BOILER N	,	BASEB Lineal Ft. @ 200°l Water Ten (1 GPM FI	Req'd. F. Avg. Iperature	Estim End C or End	aps Boxes	Heat Loss Total BTUH			R BOILER N		BASEB Lineal Ft. @ 200° Water Ten (1 GPM FI	. Req'd. F. Avg. nperature	End	nated Caps I Boxes
Minister	VHE	Gas HE	CGM	0il 68	Therma Trim	High Trim	Therma Trim	High Trim		VHE	Gas	CGM	0il 68	Therma Trim	High Trim	Therma Trim	High Trim
30,000 31,000 32,000 33,000 34,000	3 3 3 3 3	3 3 3 3	25 25 25 25 25 25	268 268 268 268 268	44 45 47 48 50	32 33 34 35 36	12 12 12 12 12	10 10 10 10 10	70,000 71,000 72,000 73,000 74,000	4 4 4 4	4 4 5 5 5 5	4 4 4 4 4	268 268 268 268 268	101 102 105 106 108	74 76 77 78 79	20 20 20 20 20 20	14 14 14 14
35,000 36,000 37,000 38,000 39,000	3 3 3 3 3	3 3 3 3 3	25 25 25 25 25 3	268 268 268 268 268	51 53 54 56 57	37 38 39 40 42	12 12 12 12 12	10 10 10 10 10	75,000 76,000 77,000 78,000 79,000	4 4 5 5 5	5 5 5 5 5	4 5 5 5 5	368 368 368 368 368	109 111 112 114 115	80 81 82 83 84	20 20 20 20 22 22	16 16 16 16
40,000 41,000 42,000 43,000 44,000	3 3 3 3 3	3 3 3 3	3 3 3 3 3	268 268 268 268 268 268	58 60 61 63 64	43 44 45 46 47	12 12 12 14 14	10 10 10 10 10	80,000 81,000 82,000 83,000 84,000	5 5 5 5 5	5 5 5 5 5	5 5 5 5 5	368 368 368 368 368	116 118 119 121 122	85 86 87 88 89	22 22 22 22 22 22	16 16 16 16
45,000 46,000 47,000 48,000 49,000	3 3 3 3	3 3 3 4	3 3 3 3 3	268 268 268 268 268	66 67 69 70 72	48 49 50 51 52	14 14 14 14	10 11 11 11	85,000 86,000 87,000 88,000 89,000	5 5 5 5	5 5 5 5 5	5 5 5 5	368 368 368 368 368	124 125 127 128 129	90 91 93 94 95	22 22 22 22 22 22	17 17 17 17
50,000 51,000 52,000 53,000 54,000	3 3 4 4 4	4 4 4 4	3 4 4 4 4	268 268 268 268 268	73 74 76 77 79	53 54 55 56 57	14 16 16 16 16	11 11	90,000 91,000 92,000 93,000 94,000	5 5 5 5	5 5 5 5	5 5 5 5 5	368 368 368 368 368	131 132 134 135 137	96 97 98 99	22 22 22 22 22 22	17 17 17 17
55,000 56,000 57,000 58,000 59,000	4 4 4 4	4 4 4 4	4 4 4 4	268 268 268 268 268	80 82 83 85 86	59 60 61 62 63	16 16 16 16 16	13 13 13 13 13	95,000 96,000 97,000 98,000 99,000	5 5 5 5	5 6 6 6	5 5 5 5 5	368 368 368 368 368	138 140 141 143 144	101 102 103 104 105	22 22 24 24 24 24	17 17 17 17 17
60,000 61,000 62,000 63,000 64,000	4 4 4 4	4 4 4 4	4 4 4 4	268 268 268 268 268 268	87 89 90 92 93	64 65 66 67 68	18 18 18 18 18	13 13 13 13 13	100,000 101,000 102,000 103,000 104,000	5 5 6 6	6 6 6	5 6 6 6	468 468 468 468 468	145 147 148 150 151	106 107 109 110 111	24 24 24 24 24	17 17 17 17 17
65,000 66,000 67,000 68,000 69,000	4 4 4 4 4	4 4 4 4 4	4 4 4 4 4	268 268 268 268 268 268	95 96 98 99 100	69 70 71 72 73	18 18 18 18 18	14 14 14 14 14	105,000 106,000 107,000 108,000 109,000 110,000	6 6 6 6	6 6 6 6 6	6 6 6 6	468 468 468 468 468 468	152 154 156 157 158 160	112 113 114 115 116 117	24 24 24 24 24 24 24	19 19 19 19 19

For number of lineal feet of baseboard required at other average water temperatures multiply lineal feet required for 200°F., Average Water Temperature by factors shown at right,

Average Water Temperature 180°F

190°F 210°F Multiplier 1 22 1.10 0.92

Note: When total heat loss exceeds 110,000 BTUH, consult rating tables in Weil-McLain product literature.

STEP 3. DETERMINE CIRCUIT AND TRUNK PIPE SIZING

The Pipe Sizing Table on Page 7 is based upon "standard" type circulators with a maximum of a 20°F, temperature drop.

All circuits are designed for use with 1/2" or 3/4" piping in single or multiple series loop circuits. Where

total heat loss found in *STEP 1* exceeds the capacity of one 3/4" loop circuit, two or more loop circuits must be used and supplied from a 3/4", 1" or 1-1/4" trunk main which has a capacity equal to or exceeding the total heat loss.

(a) Determine total measured length of entire SINGLE circuit or total measured length of circuit No. 1, including the convector baseboard; determine the heating load of circuit No. 1; determine the pipe size of the circuit and record all data here. Repeat for additional circuits when required.

(b) Determine the total length of the longest Circuit noted above, determine the total heating load handled by the TRUNK main, determine the pipe size of the trunk main and record all data here:

*Do not exceed 3/4" pipe for individual circuits.

Example:

Using the previous example of a 26' x 50' house with a total heating load of 58,280 BTU, it can be assumed that a single loop circuit measured length will be at least 26' +26' +50' +50' +10' =162' (See piping layout). Opposite 58,000 BTUH in the Pipe Sizing Table, it is shown that 1" pipe is needed. Since loops are limited to 3/4" piping because of the 3/4" baseboard tube size, the system must be laid out in at least two loops.

In this example there will be three loops, as you will recall from *STEP 1* that the owner wanted three zones — two on the first floor and one in the basement.

When estimating the pipe sizes for the first floor loops, it is necessary to determine the heating load carried by each loop. Since the living area usually carries the greater load because of larger glass areas, we will assume that the living area loop will carry a load of 24,000 BTUH and the sleeping area loop a load of 18,940 BTUH. Assume also that the measured length of each floor loop is 26' + 26' + 25' + 25' + 10' = 112'.


Length of LONGEST circuit = ______ feet
BTUH load of trunk main = _____ BTUH
Size of trunk main piping = _____

Opposite 24,000 BTUH in the Pipe Sizing Table it is shown that a 3/4" loop up to 268' will be adequate. Opposite 19,000 BTUH it is found that 1/2" pipe will be adequate for only up to 109' measured loop length and is therefore not large enough for this example. Hence, each first floor loop must be 3/4" piping.

The basement heating load is 15,340 BTUH. Assuming that the entire basement load is on a single circuit of 112' measured length (see piping layout) it is shown in the Pipe Sizing Table that 1/2" pipe will handle this load for up to 160'. The baseboard elements in the basement will still be 3/4", but all basement loop piping can be 1/2" copper tubing.

The pipe size of the supply and return trunk main is determined from the total heating load of 58,280 BTUH and from the longest loop length which is 112'. Entering the Pipe Sizing Table at 58,000 BTUH, it is shown that a 1" pipe will handle the load up to a measured loop length of 187'. The trunk main will therefore be a 1" pipe or tube.





PIPE SIZING TABLE

Maximum measured length of loop and trunk, including baseboard. Pump head 7.5 ft.--20° temperature drop.

Trunk or Circuit				Piping Dim	nensions		***************************************		Trunk Load		Piping	Dimensio	ons
Load BTUH	Size	Length	Size	Length	Size	Length	Size	Length	BTÜH	Size	Length	Size	Length
5,000 6,000 7,000 8,000 9,000	1/2" 1/2" 1/2" 1/2" 1/2" 1/2"	1,120 900 710 555 444							67,000 68,000 69,000 70,000 71,000	1 / / / / / / / / / / / / / / / / / / /	146 143 140 137 132	1 1/4" 1 1/4" 1 1/4" 1 1/4"	535 523 511 498 486
10,000 11,000 12,000 13,000 14,000	Y2" Y2" Y2" Y2" Y2"	354 300 260 218 182	3/4" 3/4"	930 830	And the second sec				72,000 73,000 74,000 75,000 76,000	The state of the s	128 125 121 119 115	1 1/4" 1 1/4" 1 1/4"	473 461 449 439 430
15,000 16,000 17,000 18,000 19,000	V2" V2" V2" V2" V2" V2"	160 140 125 112 109	3/4" 3/4" 3/4" 3/4" 3/4"	725 620 545 465 420					77,000 78,000 79,000 80,000 81,000	1 " 1 " 1 " 1 " 1 " 1 " 1 " 1 " 1 " 1 "	112 109 107 105 102	1 1/4" 1 1/4" 1 1/4" 1 1/4"	421 411 401 392 383
20,000 21,000 22,000 23,000 24,000	V2" V2" V2"	93 86 80	3/4" 3/4" 3/4" 3/4" 3/4"	372 342 310 290 268					82,000 83,000 84,000 85,000 86,000	1 " " " " " " " " " " " " " " " " " " "	100 98 95 93 92	1 1/4" 1 1/4" 1 1/4" 1 1/4"	373 366 358 351 343
25,000 26,000 27,000 28,000 29,000		oversitätiikele kan	3/4" 3/4" 3/4" 3/4" 3/4"	250 233 220 208 187	Annual of the property of the				87,000 88,000 89,000 90,000 91,000		91 89 87 86 84	1 ¼" 1 ¼" 1 ¼" 1 ¼"	336 328 321 314 307
30,000 31,000 32,000 33,000 34,000		The state of the s	3/4" 3/4" 3/4" 3/4" 3/4"	178 169 156 150 143	1 // // // // // // // // // // // // //	630 606 560 525 504			92,000 93,000 94,000 95,000 96,000	1"	82 80	1 ¼" 1 ¼" 1 ¼" 1 ¼" 1 ¼"	300 293 287 280 275
35,000 36,000 37,000 38,000 39,000			3/4" 3/4" 3/4" 3/4" 3/4"	139 133 125 117 113	1"	476 450 430 410 390			97,000 98,000 99,000 100,000 101,000			1 1/4" 1 1/4" 1 1/4" 1 1/4"	271 267 263 258 254
40,000 41,000 42,000 43,000 44,000			3/4" 3/4" 3/4" 3/4" 3/4"	110 103 99 96 93	1" 1" 1"	373 360 347 334 320	and the state of t		102,000 103,000 104,000 105,000 106,000	·		1 1/4" 1 1/4" 1 1/4" 1 1/4"	249 246 242 239 235
45,000 46,000 47,000 48,000 49,000	And the state of t				1"	307 293 280 270 259			107,000 108,000 109,000 110,000 111,000			11/4"	231 228 224 219 214
50,000 51,000 52,000 53,000 54,000					1 H	250 240 232 224 217			112,000 113,000 114,000 115,000 116,000			1/4 " 1/4 " 1/4 " 1/4 " 1/4 "	209 204 201 197 193
55,000 56,000 57,000 58,000 59,000			A CONTRACTOR CONTRACTO		1" 1" 1" 1"	210 204 195 187 184			117,000 118,000 119,000 120,000 121,000			11/4"	190 187 185 183 181
60,000 61,000 62,000 63,000 64,000 65,000		More de la companya d			1"	177 173 166 160 157 153 149	1 1/4" 1 1/4" 1 1/4" 1 1/4" 1 1/4" 1 1/4"	653 635 616 597 579 560 547	122,000 123,000 124,000 125,000 126,000 127,000 128,000			9 1/4 " 9 1/4 " 9 1/4 " 9 1/4 " 9 1/4 "	179 177 175 173 172 170 168

STEP 4. ESTIMATE THE PRICE

Page 8 of this booklet lists the material required for a residential heating system. Boiler, baseboard and trim pieces can be priced from our current price sheet. The price of pipe, fittings, etc., can be quickly estimated from past experience, using this page as a check list.

When an I = B = R heat loss has been calculated, the contractor can complete the page in order to determine the exact price of the job.

MATERIAL LIST

γTΥ.	ITEM	AMOUN	r QTY.	ITEM	AMOUN'
	Boiler Model No.			Sub-Total Brought Forward	
	DOE Efficiency Rating			Standard Splice Set	
	Thermostats			14" Splice Set	
	Zone Valves			Element Bracket	
	Balancing Valves			Element Glide	
	Air Cushion Tank			Return Tube Hanger	
	Flow Control Valve			Supply Tube Hanger	
	Low Limit or Reverse Acting Control				
	Pressure Reducing Valve				
	Smoke Pipe				
				Return Bend Fitting	
	Extra Valves			Floor Grommet	
***************************************	Gas Piping			Flexible Riser Connector	
	Oil Tank, Pipe and Fittings			(with) (without) coupling	
	Pipe			Flexible Corner Connector	
	Fuel Valves			Expansion Joint	
	Circulators			DADAMSON OVER	
ng-aminorani	Relay				
	Circuit Breaker (or fuse) Panel				
	240v. Disconnect Switch	-			
	240v. 3-Wire Service Cable				
	Copper Pipe: 1/2"				
	3/4"				
	1"				
	Fittings				
A	Lineal Feet of Baseboard				
	Baseboard Accessories:				
	End Cap R.H.			Electric Wiring	
	End Cap L.H.			Freight and Cartage	
	End Box R.H.			Incidentals	
	End Box L.H.				
	Valve Box R. H.			TOTAL COST OF MATERIAL	
	Valve Box L.H.			Labor	
	Inside Corner (With Filler)			Profit	
***************************************	Outside Corner			Overhead	
	Inside Bay Corner (With Filler)	+ +			
	SUB-TOTAL	+		Bid Price	

STEP 5. MAKE I=B=R CALCULATION

Once a job has been sold a complete I = B = R calculation should be made to accurately locate baseboard panels in each room. Refer to I = B = R heat loss calculation guide.

OTHER MATERIALS AVAILABLE TO AID IN HEAT LOSS CALCULATIONS

- Easy-Loop Worksheet—Form No. C-566—to be used in conjunction with your Easy-Loop Booklet.
- "Modern Method" Heat Loss Calculation Sheet—Form No. MC-1407.
- "Detailed Method" I = B = R Heat Loss Calculation Sheet—Form No. MC-1956.

Contact Your Local Weil-McLain Distributor or Field Representative or write to: Advertising Dept., Weil-McLain, Blaine St., Michigan City, IN 46360