



Series 2
Gas-Fired Water Boilers
with Tankless Heater

Addendum DOE Output Correction'S

KEEP THIS ADDENDUM WITH BOILER MANUAL

Replace the Ratings Table on page 67 of the CGt Series 1 Boiler Manual with the following table:




Table 9 Boiler ratings

Boiler model number	DOE Heating capacity (Btuh)	Input (Btuh)	Output (Btuh)	Net AHRI ratings (Btuh)	Boiler water content (gallons)	DOE Seasonal efficiency (% AFUE)	Vent size	
							Direct exhaust	Chimney draft
	(Note 1)			(Note 2)			(Note 3)	
CGt-PIN	109,000	133,000	109,000	94,000	3.1	82.1	3"	5"
Notes	<p>1. Based on standard test procedures prescribed by the United States Department of Energy.</p> <p>2. Net AHRI ratings are based on net installed radiation of sufficient quantity for the requirements of the building and nothing need be added for normal piping and pickup. Ratings are based on a piping and pickup allowance of 1.15. An additional allowance should be made for unusual piping and pickup loads.</p> <p>3. Direct exhaust CGt boilers require special venting, consistent with Category III boilers. Use only the vent materials and methods specified in this manual. Chimney draft vented CGt boilers may use type B vent or other materials suitable for venting Category I boilers.</p>							