

CAEP

Submittal Documents

Seismic Analysis of the Boiler SF 750



June 24, 2019

For:
WEIL-McLAIN

Prepared By:
Sam Salissen, ME, PE, Ph.D.

Summary

The scope of this report is the seismic qualification, based on the structural analysis, of the Slim Fit boiler model 750, under the seismic loads for the seismic zone 4 in the United States. The analyses are limited to the load path from the COG of the assembly to the floor and the interior parts of the boiler are not within the scope of this work.

The qualification is in accordance with the seismic design requirements of IBC 2015, ASCE 7-10 and AISC 14th edition for the seismic zone 4, for non-structural components and based on the seismic parameters used in this report.

The structural analyses carried out on the base frame assembly and based on the safety factors reported in section 5.4, the design requirements of AISC, is met in all the analyses performed in this report.

It is concluded that the design of the main frame and seismic stands meets the design requirements of IBC 2015, ASCE 7-10 and ASME BPVC and AISC standards. This conclusion is contingent to the accuracy of the SolidWorks model and other input data provided by WEIL-McLAIN (WM) and used to build the FE models and set up the analyses (material, COG,...) appended in Appendix 1.

Revision History

Rev	Date	Scope of the revision	Created by
A	06/24/2019	First Issue	Sam Salissen

Table of Contents

1	Introduction	6
1.1	Scope	6
2	Assumptions and open issues	6
3	Requirements and Prerequisites.....	7
3.1	Stress criteria	7
3.2	Loads	7
4	Analyses' model	9
4.1	The extent of the model.....	9
4.2	Material data.....	9
5	Stress Analyses.....	10
5.1	Analysis of assembly: Load Case 1	10
5.2	Analysis of assembly: Load Case 2	11
5.3	Analysis of assembly: Load Case 3	12
5.3.1	Anchor Bolts	14
5.4	Results Evaluation.....	14
6	Conclusion	15
7	References	16

APPENDICES

APPENDIX 1- Overall dimension of the boilers

APPENDIX 2- Anchor Bolt Calculation Report

1 Introduction

1.1 Scope

The scope of this report is the seismic qualification, based on the structural analysis, of the Slim Fit boiler model 750, under the seismic loads for the seismic zone 4 in the states. The analyses are limited to the load path from the COG of the assembly to the floor and the interior parts of the boiler are not within the scope of this work. The qualification is in accordance with the design requirements of IBC 2015, ASCE 7-10 and AISC.

2 Assumptions and open issues

In this chapter, assumptions and open issues are presented in two categories. The definition of each is presented below.

Open issues- Is defined as issues that must be solved, otherwise the analysis cannot be completed.

Key assumption- Is defined as assumptions that may have noticeable impact on the analysis results.

2.1 Open Issues

- No open issues exist.

2.2 Key Assumptions

No fabrication drawing of the parts and assembly were provided and the analyses are based on the SolidWorks model that is provided by WM and no responsibility of the accuracy of the model with respect to the actual assembly will be taken by the author of this report.

- The weight and the location of the center of the gravity of the boiler assembly are estimated and provided by WM, Appendix 1.
- It is assumed that the material of the base frame and the top plate are S235JR.
- It is assumed that the welds have at least the same strength as the base material (Weld strength $F_{EXX} = 70 \text{ksi} > 54 \text{ksi}$ for base material) based on ASME allowable stress in welds under shear and tension is $0.3 * \text{tensile strength} = 21000 \text{psi}$. In this case it is lower than the allowable stress of the in the members (AISC). So, no weld analysis will be performed in this work.
- It is assumed that no load will be transferred from the connecting piping system to the boiler during a seismic event, flex joint will be needed at the connection points.

3 Requirements and Prerequisites

3.1 Stress criteria

The seismic loads are calculated based on the IBC 2015 code. The detail of the used parameters and the calculations are as follows. Seismic analyses are performed (using FEM) based on ASD approach of the AISC 14 edition & ASCE 7-10 for the steel parts and LRFD for the anchorage calculations.

3.2 Loads

The following inputs are used for the weight of the boilers.

Boiler Model	Shipping weight	Operating weight	Water content	Water flow rate per boiler		Vent/air pipe size – Provide a separate vent for each boiler	Electrical service required
	Pounds per boiler	Pounds per boiler Note 2	Gallons per boiler	GPM @ 30°F rise	GPM @ 40°F rise		Amps per boiler Note 4
SF-550	505	476	5.5	34	26	6" or 8"	25 (boiler) 15 (Boiler Circulator)
SF-750	550	529	6.5	47	35	6" or 8"	25 (boiler) 15 (Boiler Circulator)

Three load cases are considered in this report, the analyses are based on the worst load combinations specified in ASCE 7-10. The following parameters are used in calculation of the seismic loads as follows:

- 1- Load case 1: Used for the analyses of the steel parts



14271 Jeffrey Rd,
Irvine, CA 90032
PH (949) 923 9073 FX (949) 264 7184
www.caepiping.com
"CALL US - TO SET THINGS RIGHT"

JOB NAME:
SA-SF 750

CUSTOMER:
WEIL-McLAIN

DATE	PRP. BY:	CAE PIPING JOB #
6/24/2019		

SEISMIC CALCULATION WORKSHEET

BUILDING CODE
IBC-2012 / 2015

SEISMIC DESIGN BLDG. ELEVATION
S_{ds} = 2 / EQUIP. LOCATION

l_p = 1 h = 40 ft

a_p = 1 **z = 40 ft

R_p = 2.5 ** Assume worst

Ω_o = 2.0 case location.

a_p, R_p, Ω_o per ASCE 7-10

40 ft. RF
 0 ft. GF
 or below ground

LOAD COMBINATION

LRFD

(1.2 DL + 1.00 E)

EQUIPMENT Information:

W_p = max. operating weight = 600 lbs.

APPLIED SEISMIC FORCE/ CALCULATIONS:

$F_p / W_p = (0.4 \times a_p \times S_{ds} \times (1 + (2 \times (z / h)) / (R_p / l_p))) = 0.96$

$F_p / W_p = 0.96g$; $F_{p,min} / W_p = 0.3 \times S_{ds} \times l_p = 0.60$; $F_{p,max} / W_p = 1.6 \times S_{ds} \times l_p = 3.20$

F_{ph} = Applied Lateral Seismic Force = 1.0 x 0.96g x W_p = 576 lbs. *WORST CASE

F_{pv} = Vertical component of seismic force = 1.0 x 0.2 x S_{ds} x W_p = 240 lbs. *WORST CASE

F_v = Vertical total load = F_{pv} - 9"W_p = -300 lbs.

ANCHORAGE TO CONCRETE

SHT. NUMBER: 1 OF 1

2- Load case 2: Used for the analyses of the steel parts



14271 Jeffrey Rd,
Invine, CA 90032
PH (949) 923 9073 FX (949) 264 7184
www.caepiping.com
"CALL US - TO SET THINGS RIGHT"

JOB NAME:
SA-SF 750

CUSTOMER:
WEIL-McLAIN

DATE: 6/24/2019 PRP. BY: CAE PIPING JOB#

SEISMIC CALCULATION WORKSHEET

BUILDING CODE
IBC-2012 / 2015

SEISMIC DESIGN BLDG. ELEVATION
 $S_{ds} = 2$ /EQUIP. LOCATION

$I_p = 1$ $h = 40$ ft
 $a_p = 1$ $z = 40$ ft

$R_p = 2.5$ ** Assume worst case location
 $\Omega_o = 2.0$

a_p, R_p, Ω_o per ASCE 7-10

ANCHORAGE TO CONCRETE
 40 ft. RF

 0 ft. GF
or below ground

LOAD COMBINATION
LRFD
(**0.9 DL + 1.00 E**)

EQUIPMENT TAG: SLIM FIT 2000

EQUIPMENT Information:
 $W_p = \text{max. operating weight} = 600 \text{ lbs.}$

APPLIED SEISMIC FORCE/ CALCULATIONS:

$F_p / W_p = (0.4 \times a_p \times S_{ds} \times (1 + (2 \times (z / h)))) / (R_p / I_p) = 0.96$	ANCHORAGE TO CONCRETE	SHT. NUMBER
$F_p / W_p = 0.96g$; $F_{p,min} / W_p = 0.3 \times S_{ds} \times I_p = 0.60$; $F_{p,max} / W_p = 1.6 \times S_{ds} \times I_p = 3.20$		1 OF 1
$F_{ph} = \text{Applied Lateral Seismic Force} = 1.0 \times 0.96g \times W_p = 576 \text{ lbs.}$		"WORST CASE"
$F_{pv} = \text{Vertical component of seismic force} = 1.0 \times 0.2 \times S_{ds} \times W_p = 240 \text{ lbs.}$		"WORST CASE"
$F_v = \text{Vertical total load} = F_{pv} - .9 \times W_p = -300 \text{ lbs.}$		

3- Load case 3: Used in the analyses of the anchorage



14271 Jeffrey Rd,
Invine, CA 90032
PH (949) 923 9073 FX (949) 264 7184
www.caepiping.com
"CALL US - TO SET THINGS RIGHT"

JOB NAME:
SA-SF 750

CUSTOMER:
WEIL-McLAIN

DATE: 6/24/2019 PRP. BY: CAE PIPING JOB#

SEISMIC CALCULATION WORKSHEET

BUILDING CODE
IBC-2012 / 2015

SEISMIC DESIGN BLDG. ELEVATION
 $S_{ds} = 2$ /EQUIP. LOCATION

$I_p = 1$ $h = 40$ ft
 $a_p = 1$ $z = 40$ ft

$R_p = 2.5$ ** Assume worst case location
 $\Omega_o = 2.0$

a_p, R_p, Ω_o per ASCE 7-10

ANCHORAGE TO CONCRETE
 40 ft. RF

 0 ft. GF
or below ground

LOAD COMBINATION
LRFD 2013
(**0.9 DL + 2.50 E**)

EQUIPMENT TAG: SLIM FIT 2000

EQUIPMENT Information:
 $W_p = \text{max. operating weight} = 600 \text{ lbs.}$

APPLIED SEISMIC FORCE/ CALCULATIONS:

$F_p / W_p = (0.4 \times a_p \times S_{ds} \times (1 + (2 \times (z / h)))) / (R_p / I_p) = 0.96$	ANCHORAGE TO CONCRETE	SHT. NUMBER
$F_p / W_p = 0.96g$; $F_{p,min} / W_p = 0.3 \times S_{ds} \times I_p = 0.60$; $F_{p,max} / W_p = 1.6 \times S_{ds} \times I_p = 3.20$		1 OF 1
$F_{ph} = \text{Applied Lateral Seismic Force} = 2.5 \times 0.96g \times W_p = 1440 \text{ lbs.}$		"WORST CASE"
$F_{pv} = \text{Vertical component of seismic force} = 1.0 \times 0.2 \times S_{ds} \times W_p = 240 \text{ lbs.}$		"WORST CASE"
$F_v = \text{Vertical total load} = F_{pv} - .9 \times W_p = -300 \text{ lbs.}$		

The seismic (& dead weights) loads are applied at the location of the center of the gravity of boiler's assembly, using rigid elements, see Fig. 1.




Figure 1- Loads acting on the boiler structure

5.3.1 Bolts

Hilti KBZ anchor bolts, 3/8" (2 3/4" embedment), are used to anchor the base plates to the floor and the side tube to the wall. The maximum reaction loads at the location of the joints are extracted from the FE-analyses (load case 3 above). The detail of the anchor bolt calcs are provided in Appendix 3. The minimum concrete thickness of 5" and PSI rating of 3.000 psi are considered in the analyses).

Table-3: Reaction loads in the base plate

Reaction forces [lbf]			Reaction moments [lbf-ft]		
FX	FY	FZ	MX	MY	MZ
40	75	180	135	15	20

Table-4: Reaction loads in the side anchor bolts

Reaction forces [lbf]		
FX	FY	FZ
5	40	596

3/8" grade 5 steel bolts are needed for jointing the angles to the longitudinal tubes in front of the frame. The maximum reaction loads on these bolts are listed in the following.

Table-5: Reaction loads in the bolts of angles holding the longitudinal tubes

Reaction forces [lbf]		
FX	FY	FZ
190	5	25

5.4 Results Evaluation

Minimum required strength specified in ASCE is obtained in the analyses of the supporting frame assembly carried out in sections 5.1 to 5.4. The stresses reported in section 5 are the local stresses and the average stress through the thickness of the members are much lower and that can be shown by stress linearization through the thickness. However, since even the maximum local peak stresses don't exceed the allowable values, the stress linearization work is skipped here.

6 Conclusion

Seismic analysis of the boiler, model SF 750, is carried out in this report and based on the safety factors reported in section **5.4**, minimum required strength factor is obtained in all the analyses performed in this report.

It is concluded that the design of the structure of the boiler SF-1000 meets the design requirements of AISC, ASCE7-10 and IBC 2012 standards.


7 *References*

[1]- IBC 2012.

[2]- AISC 14th Edition.

[3]- ASCE 7-10.

APPENDIX I- Overall dimensions of boiler



Appendix 2- Anchor Bolt Calculation


www.hilti.us

Company: CAE PIPING
 Specifier: SAM SALISSEN
 Address:
 Phone | Fax: |
 E-Mail:

Page: 1
 Project: ANCHOR BOLTS
 Sub-Project | Pos. No.:
 Date: 6/24/2019

Specifier's comments:
1 Input data

Anchor type and diameter:	Kwik Bolt TZ - CS 3/8 (2 3/4)	
Effective embedment depth:	$h_{ef,act} = 2.750$ in., $h_{nom} = 3.063$ in.	
Material:	Carbon Steel	
Evaluation Service Report:	ESR-1917	
Issued Valid:	6/1/2016 5/1/2017	
Proof:	Design method ACI 318-14 / Mech.	
Stand-off installation:	$e_b = 0.000$ in. (no stand-off); $t = 0.250$ in.	
Anchor plate:	$l_x \times l_y \times t = 4.000$ in. \times 6.000 in. \times 0.250 in.; (Recommended plate thickness: not calculated)	
Profile:	no profile	
Base material:	cracked concrete, 2500, $f_c' = 2500$ psi; $h = 5.000$ in.	
Installation:	hammer drilled hole, Installation condition: Dry	
Reinforcement:	tension: condition B, shear: condition B; no supplemental splitting reinforcement present edge reinforcement: none or < No. 4 bar	

Geometry [in.] & Loading [lb, ft.lb]


www.hilti.us

Company: CAE PIPING
 Specifier: SAM SALISSEN
 Address:
 Phone | Fax: |
 E-Mail:

Page: 2
 Project: ANCHOR BOLTS
 Sub-Project | Pos. No.:
 Date: 6/24/2019

2 Load case/Resulting anchor forces


Load case: Design loads

Anchor reactions [lb]

Tension force: (+Tension, -Compression)

Anchor	Tension force	Shear force	Shear force x	Shear force y
1	17	109	61	90
2	381	94	-26	90

max. concrete compressive strain: 0.07 [‰]
 max. concrete compressive stress: 311 [psi]
 resulting tension force in (x/y)=(0.000/1.889): 398 [lb]
 resulting compression force in (x/y)=(0.744/-2.692): 323 [lb]



3 Tension load

	Load N_{ua} [lb]	Capacity ϕN_n [lb]	Utilization $\beta_N = N_{ua}/\phi N_n$	Status
Steel Strength*	381	4875	8	OK
Pullout Strength*	381	2051	19	OK
Concrete Breakout Strength**	398	2592	16	OK

* anchor having the highest loading **anchor group (anchors in tension)

3.1 Steel Strength

N_{sa} = ESR value refer to ICC-ES ESR-1917
 $\phi N_{sa} \geq N_{ua}$ ACI 318-14 Table 17.3.1.1

Variables

$A_{se,N}$ [in. ²]	f_{uta} [psi]
0.05	125000

Calculations

N_{sa} [lb]
6500

Results

N_{sa} [lb]	ϕ_{steel}	ϕN_{sa} [lb]	N_{ua} [lb]
6500	0.750	4875	381

www.hilti.us

 Company: CAE PIPING
 Specifier: SAM SALISSEN
 Address:
 Phone | Fax: |
 E-Mail:

 Page: 3
 Project: ANCHOR BOLTS
 Sub-Project | Pos. No.:
 Date: 6/24/2019

3.2 Pullout Strength

$$N_{pn,f_c} = N_{p,2500} \lambda_a \sqrt{\frac{f_c}{2500}} \quad \text{refer to ICC-ES ESR-1917}$$

$$\phi N_{pn,f_c} \geq N_{ua} \quad \text{ACI 318-14 Table 17.3.1.1}$$

Variables

f_c [psi]	λ_a	$N_{p,2500}$ [lb]
2500	1.000	3155

Calculations

$$\frac{\sqrt{\frac{f_c}{2500}}}{1.000}$$

Results

N_{pn,f_c} [lb]	$\phi_{concrete}$	$\phi N_{pn,f_c}$ [lb]	N_{ua} [lb]
3155	0.650	2051	381

3.3 Concrete Breakout Strength

$$N_{cbg} = \left(\frac{A_{Nc}}{A_{Nc0}} \right) \psi_{ec,N} \psi_{ed,N} \psi_{c,N} \psi_{cp,N} N_b \quad \text{ACI 318-14 Eq. (17.4.2.1b)}$$

$$\phi N_{cbg} \geq N_{ua} \quad \text{ACI 318-14 Table 17.3.1.1}$$

$$A_{Nc} \text{ see ACI 318-14, Section 17.4.2.1, Fig. R 17.4.2.1(b)}$$

$$A_{Nc0} = 9 h_{ef}^2 \quad \text{ACI 318-14 Eq. (17.4.2.1c)}$$

$$\psi_{ec,N} = \left(\frac{1}{1 + \frac{2 e_{c,N}}{3 h_{ef}}} \right) \leq 1.0 \quad \text{ACI 318-14 Eq. (17.4.2.4)}$$

$$\psi_{ed,N} = 0.7 + 0.3 \left(\frac{c_{a,min}}{1.5 h_{ef}} \right) \leq 1.0 \quad \text{ACI 318-14 Eq. (17.4.2.5b)}$$

$$\psi_{cp,N} = \text{MAX} \left(\frac{c_{a,min}}{c_{ac}}, \frac{1.5 h_{ef}}{c_{ac}} \right) \leq 1.0 \quad \text{ACI 318-14 Eq. (17.4.2.7b)}$$

$$N_b = k_c \lambda_a \sqrt{f_c} h_{ef}^{1.5} \quad \text{ACI 318-14 Eq. (17.4.2.2a)}$$

Variables

h_{ef} [in.]	$e_{c1,N}$ [in.]	$e_{c2,N}$ [in.]	$c_{a,min}$ [in.]	$\psi_{c,N}$
2.750	0.000	1.889	10.000	1.000
c_{ac} [in.]	k_c	λ_a	f_c [psi]	
4.125	17	1.000	2500	

Calculations

A_{Nc} [in. ²]	A_{Nc0} [in. ²]	$\psi_{ec1,N}$	$\psi_{ec2,N}$	$\psi_{ed,N}$	$\psi_{cp,N}$	N_b [lb]
102.09	68.06	1.000	0.686	1.000	1.000	3876

Results

N_{cbg} [lb]	$\phi_{concrete}$	ϕN_{cbg} [lb]	N_{ua} [lb]
3988	0.650	2592	398

www.hilti.us

 Company: CAE PIPING
 Specifier: SAM SALISSEN
 Address:
 Phone | Fax: |
 E-Mail:

 Page: 4
 Project: ANCHOR BOLTS
 Sub-Project | Pos. No.:
 Date: 6/24/2019

4 Shear load

	Load V_{ua} [lb]	Capacity ϕV_n [lb]	Utilization $\beta_V = V_{ua}/\phi V_n$	Status
Steel Strength*	109	2337	5	OK
Steel failure (with lever arm)*	N/A	N/A	N/A	N/A
Pryout Strength*	109	4070	3	OK
Concrete edge failure in direction y+**	190	2720	7	OK

* anchor having the highest loading **anchor group (relevant anchors)

4.1 Steel Strength

 V_{sa} = ESR value refer to ICC-ES ESR-1917
 $\phi V_{steel} \geq V_{ua}$ ACI 318-14 Table 17.3.1.1

Variables

$A_{se,V}$ [in. ²]	f_{uta} [psi]
0.05	125000

Calculations

V_{sa} [lb]
3595

Results

V_{sa} [lb]	ϕ_{steel}	ϕV_{sa} [lb]	V_{ua} [lb]
3595	0.650	2337	109

4.2 Pryout Strength

$$V_{cp} = k_{cp} \left[\left(\frac{A_{Nc}}{A_{Nc0}} \right) \psi_{ed,N} \psi_{c,N} \psi_{cp,N} N_b \right] \quad \text{ACI 318-14 Eq. (17.5.3.1a)}$$

$$\phi V_{cp} \geq V_{ua} \quad \text{ACI 318-14 Table 17.3.1.1}$$

$$A_{Nc} \text{ see ACI 318-14, Section 17.4.2.1, Fig. R 17.4.2.1(b)}$$

$$A_{Nc0} = 9 h_{ef}^2 \quad \text{ACI 318-14 Eq. (17.4.2.1c)}$$

$$\psi_{ec,N} = \left(\frac{1}{1 + \frac{2 e_N}{3 h_{ef}}} \right) \leq 1.0 \quad \text{ACI 318-14 Eq. (17.4.2.4)}$$

$$\psi_{ed,N} = 0.7 + 0.3 \left(\frac{c_{a,min}}{1.5 h_{ef}} \right) \leq 1.0 \quad \text{ACI 318-14 Eq. (17.4.2.5b)}$$

$$\psi_{cp,N} = \text{MAX} \left(\frac{c_{a,min}}{c_{ac}}, \frac{1.5 h_{ef}}{c_{ac}} \right) \leq 1.0 \quad \text{ACI 318-14 Eq. (17.4.2.7b)}$$

$$N_b = k_c \lambda_a \sqrt{f'_c} h_{ef}^{1.5} \quad \text{ACI 318-14 Eq. (17.4.2.2a)}$$

Variables

k_{cp}	h_{ef} [in.]	$e_{c1,N}$ [in.]	$e_{c2,N}$ [in.]	$c_{a,min}$ [in.]
2	2.750	0.000	0.000	10.000

$\psi_{c,N}$	c_{ac} [in.]	k_c	λ_a	f'_c [psi]
1.000	4.125	17	1.000	2500

Calculations

A_{Nc} [in. ²]	A_{Nc0} [in. ²]	$\psi_{ec1,N}$	$\psi_{ec2,N}$	$\psi_{ed,N}$	$\psi_{cp,N}$	N_b [lb]
51.05	68.06	1.000	1.000	1.000	1.000	3876

Results

V_{cp} [lb]	$\phi_{concrete}$	ϕV_{cp} [lb]	V_{ua} [lb]
5814	0.700	4070	109

www.hilti.us

Company: CAE PIPING
 Specifier: SAM SALISSEN
 Address:
 Phone | Fax: |
 E-Mail:

Page: 5
 Project: ANCHOR BOLTS
 Sub-Project | Pos. No.:
 Date: 6/24/2019

4.3 Concrete edge failure in direction y+

$$V_{cbg} = \left(\frac{A_{Vc}}{A_{Vc0}} \right) \Psi_{ec,V} \Psi_{ed,V} \Psi_{c,V} \Psi_{h,V} \Psi_{parallel,V} V_b \quad \text{ACI 318-14 Eq. (17.5.2.1b)}$$

$$\phi V_{cbg} \geq V_{ua} \quad \text{ACI 318-14 Table 17.3.1.1}$$

A_{Vc} see ACI 318-14, Section 17.5.2.1, Fig. R 17.5.2.1(b)

$$A_{Vc0} = 4.5 c_{a1}^2 \quad \text{ACI 318-14 Eq. (17.5.2.1c)}$$

$$\Psi_{ec,V} = \left(\frac{1}{1 + \frac{2e_v}{3c_{a1}}} \right) \leq 1.0 \quad \text{ACI 318-14 Eq. (17.5.2.5)}$$

$$\Psi_{ed,V} = 0.7 + 0.3 \left(\frac{c_{a2}}{1.5c_{a1}} \right) \leq 1.0 \quad \text{ACI 318-14 Eq. (17.5.2.6b)}$$

$$\Psi_{h,V} = \sqrt{\frac{1.5c_{a1}}{h_a}} \geq 1.0 \quad \text{ACI 318-14 Eq. (17.5.2.8)}$$

$$V_b = \left(7 \left(\frac{l_e}{d_a} \right)^{0.2} \sqrt{d_a} \right) \lambda_a \sqrt{f_c} c_{a1}^{1.5} \quad \text{ACI 318-14 Eq. (17.5.2.2a)}$$

Variables

c_{a1} [in.]	c_{a2} [in.]	e_{cV} [in.]	$\Psi_{c,V}$	h_a [in.]
6.667	10.000	0.000	1.000	5.000
l_e [in.]	λ_a	d_a [in.]	f_c [psi]	$\Psi_{parallel,V}$
2.750	1.000	0.375	2500	1.000

Calculations

A_{Vc} [in. ²]	A_{Vc0} [in. ²]	$\Psi_{ec,V}$	$\Psi_{ed,V}$	$\Psi_{h,V}$	V_b [lb]
100.00	200.00	1.000	1.000	1.414	5495

Results

V_{cbg} [lb]	$\phi_{concrete}$	ϕV_{cbg} [lb]	V_{ua} [lb]
3886	0.700	2720	190

5 Combined tension and shear loads

β_N	β_V	ζ	Utilization $\beta_{N,V}$ [%]	Status
0.186	0.070	5/3	8	OK

$$\beta_{NV} = \beta_N^{\zeta} + \beta_V^{\zeta} \leq 1$$

6 Warnings

- Load re-distributions on the anchors due to elastic deformations of the anchor plate are not considered. The anchor plate is assumed to be sufficiently stiff, in order not to be deformed when subjected to the loading! Input data and results must be checked for agreement with the existing conditions and for plausibility!
- Condition A applies when supplementary reinforcement is used. The Φ factor is increased for non-steel Design Strengths except Pullout Strength and Pryout strength. Condition B applies when supplementary reinforcement is not used and for Pullout Strength and Pryout Strength. Refer to your local standard.
- Refer to the manufacturer's product literature for cleaning and installation instructions.
- Checking the transfer of loads into the base material and the shear resistance are required in accordance with ACI 318 or the relevant standard!
- Hilti post-installed anchors shall be installed in accordance with the Hilti Manufacturer's Printed Installation Instructions (MPII). Reference ACI 318-14, Section 17.8.1.

Fastening meets the design criteria!

www.hilti.us

Company: CAE PIPING
 Specifier: SAM SALISSEN
 Address:
 Phone | Fax: |
 E-Mail:


Page: 6
 Project: ANCHOR BOLTS
 Sub-Project | Pos. No.:
 Date: 6/24/2019

7 Installation data

Anchor plate, steel: -	Anchor type and diameter: Kwik Bolt TZ - CS 3/8 (2 3/4)
Profile: no profile	Installation torque: 25.000 ft.lb
Hole diameter in the fixture: $d_f = 0.438$ in.	Hole diameter in the base material: 0.375 in.
Plate thickness (input): 0.250 in.	Hole depth in the base material: 3.375 in.
Recommended plate thickness: not calculated	Minimum thickness of the base material: 5.000 in.
Drilling method: Hammer drilled	
Cleaning: Manual cleaning of the drilled hole according to instructions for use is required.	

7.1 Recommended accessories

Drilling	Cleaning	Setting
<ul style="list-style-type: none"> • Suitable Rotary Hammer • Properly sized drill bit 	<ul style="list-style-type: none"> • Manual blow-out pump 	<ul style="list-style-type: none"> • Torque wrench • Hammer



Coordinates Anchor in.

Anchor	x	y	C-x	C+X	C-y	C+y
1	0.000	-2.063	10.000	10.000	10.000	14.125
2	0.000	2.063	10.000	10.000	14.125	10.000

www.hilti.us

Company: CAE PIPING
Specifier: SAM SALISSEN
Address:
Phone | Fax: |
E-Mail:

Page: 7
Project: ANCHOR BOLTS
Sub-Project | Pos. No.:
Date: 6/24/2019

8 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.


www.hilti.us

Company: CAE PIPING
 Specifier: SAM SALISSEN
 Address:
 Phone | Fax: |
 E-Mail:

Page: 1
 Project: SIDE ANCHOR BOLTS
 Sub-Project | Pos. No.:
 Date: 6/24/2019

Specifier's comments:
1 Input data

Anchor type and diameter:	Kwik Bolt TZ - CS 3/8 (2 3/4)
Effective embedment depth:	$h_{ef,act} = 2.750 \text{ in.}$, $h_{nom} = 3.063 \text{ in.}$
Material:	Carbon Steel
Evaluation Service Report:	ESR-1917
Issued Valid:	6/1/2016 5/1/2017
Proof:	Design method ACI 318-14 / Mech.
Stand-off installation:	- (Recommended plate thickness: not calculated)
Profile:	no profile
Base material:	cracked concrete, 2500, $f'_c = 2500 \text{ psi}$; $h = 5.000 \text{ in.}$
Installation:	hammer drilled hole, Installation condition: Dry
Reinforcement:	tension: condition B, shear: condition B; no supplemental splitting reinforcement present edge reinforcement: none or < No. 4 bar


Geometry [in.] & Loading [lb, in.lb]


www.hilti.us

Company: CAE PIPING
 Specifier: SAM SALISSEN
 Address:
 Phone | Fax: |
 E-Mail:

Page: 2
 Project: SIDE ANCHOR BOLTS
 Sub-Project | Pos. No.:
 Date: 6/24/2019

2 Load case/Resulting anchor forces

Load case: Design loads

Anchor reactions [lb]

Tension force: (+Tension, -Compression)

Anchor	Tension force	Shear force	Shear force x	Shear force y
1	1200	113	80	80

max. concrete compressive strain: - [‰]
 max. concrete compressive stress: - [psi]
 resulting tension force in (x/y)=(0.000/0.000): 0 [lb]
 resulting compression force in (x/y)=(0.000/0.000): 0 [lb]

3 Tension load

	Load N_{ua} [lb]	Capacity ϕN_n [lb]	Utilization $\beta_N = N_{ua}/\phi N_n$	Status
Steel Strength*	1200	4875	25	OK
Pullout Strength*	1200	2051	59	OK
Concrete Breakout Strength**	1200	2520	48	OK

* anchor having the highest loading **anchor group (anchors in tension)

3.1 Steel Strength

N_{sa} = ESR value refer to ICC-ES ESR-1917
 $\phi N_{sa} \geq N_{ua}$ ACI 318-14 Table 17.3.1.1

Variables

$A_{se,N}$ [in. ²]	f_{uta} [psi]
0.05	125000

Calculations

N_{sa} [lb]
6500

Results

N_{sa} [lb]	ϕ_{steel}	ϕN_{sa} [lb]	N_{ua} [lb]
6500	0.750	4875	1200

www.hilti.us

Company: CAE PIPING
 Specifier: SAM SALISSEN
 Address:
 Phone | Fax: |
 E-Mail:

Page: 3
 Project: SIDE ANCHOR BOLTS
 Sub-Project | Pos. No.:
 Date: 6/24/2019

3.2 Pullout Strength

$$N_{pn,f_c} = N_{p,2500} \lambda_a \sqrt{\frac{f_c}{2500}} \quad \text{refer to ICC-ES ESR-1917}$$

$$\phi N_{pn,f_c} \geq N_{ua} \quad \text{ACI 318-14 Table 17.3.1.1}$$

Variables

f_c [psi]	λ_a	$N_{p,2500}$ [lb]
2500	1.000	3155

Calculations

$$\frac{\sqrt{\frac{f_c}{2500}}}{1.000}$$

Results

N_{pn,f_c} [lb]	$\phi_{concrete}$	$\phi N_{pn,f_c}$ [lb]	N_{ua} [lb]
3155	0.650	2051	1200

3.3 Concrete Breakout Strength

$$N_{cb} = \left(\frac{A_{Nc}}{A_{Nc0}} \right) \Psi_{ed,N} \Psi_{c,N} \Psi_{cp,N} N_b \quad \text{ACI 318-14 Eq. (17.4.2.1a)}$$

$$\phi N_{cb} \geq N_{ua} \quad \text{ACI 318-14 Table 17.3.1.1}$$

$$A_{Nc} \text{ see ACI 318-14, Section 17.4.2.1, Fig. R 17.4.2.1(b)}$$

$$A_{Nc0} = 9 h_{ef}^2 \quad \text{ACI 318-14 Eq. (17.4.2.1c)}$$

$$\Psi_{ec,N} = \left(\frac{1}{1 + \frac{2 e_N}{3 h_{ef}}} \right) \leq 1.0 \quad \text{ACI 318-14 Eq. (17.4.2.4)}$$

$$\Psi_{ed,N} = 0.7 + 0.3 \left(\frac{C_{a,min}}{1.5 h_{ef}} \right) \leq 1.0 \quad \text{ACI 318-14 Eq. (17.4.2.5b)}$$

$$\Psi_{cp,N} = \text{MAX} \left(\frac{C_{a,min}}{C_{ac}}, \frac{1.5 h_{ef}}{C_{ac}} \right) \leq 1.0 \quad \text{ACI 318-14 Eq. (17.4.2.7b)}$$

$$N_b = k_c \lambda_a \sqrt{f_c} h_{ef}^{1.5} \quad \text{ACI 318-14 Eq. (17.4.2.2a)}$$

Variables

h_{ef} [in.]	$e_{c1,N}$ [in.]	$e_{c2,N}$ [in.]	$C_{a,min}$ [in.]	$\Psi_{c,N}$
2.750	0.000	0.000	10.000	1.000

C_{ac} [in.]	k_c	λ_a	f_c [psi]
4.125	17	1.000	2500

Calculations

A_{Nc} [in. ²]	A_{Nc0} [in. ²]	$\Psi_{ec1,N}$	$\Psi_{ec2,N}$	$\Psi_{ed,N}$	$\Psi_{cp,N}$	N_b [lb]
68.06	68.06	1.000	1.000	1.000	1.000	3876

Results

N_{cb} [lb]	$\phi_{concrete}$	ϕN_{cb} [lb]	N_{ua} [lb]
3876	0.650	2520	1200

www.hilti.us

 Company: CAE PIPING
 Specifier: SAM SALISSEN
 Address:
 Phone | Fax: |
 E-Mail:

 Page: 4
 Project: SIDE ANCHOR BOLTS
 Sub-Project | Pos. No.:
 Date: 6/24/2019

4 Shear load

	Load V_{ua} [lb]	Capacity ϕV_n [lb]	Utilization $\beta_V = V_{ua}/\phi V_n$	Status
Steel Strength*	113	2337	5	OK
Steel failure (with lever arm)*	N/A	N/A	N/A	N/A
Pryout Strength**	113	5427	3	OK
Concrete edge failure in direction x+**	113	2720	5	OK

* anchor having the highest loading **anchor group (relevant anchors)

4.1 Steel Strength

 V_{sa} = ESR value refer to ICC-ES ESR-1917
 $\phi V_{steel} \geq V_{ua}$ ACI 318-14 Table 17.3.1.1

Variables

$A_{se,V}$ [in. ²]	f_{uta} [psi]
0.05	125000

Calculations

V_{sa} [lb]
3595

Results

V_{sa} [lb]	ϕ_{steel}	ϕV_{sa} [lb]	V_{ua} [lb]
3595	0.650	2337	113

4.2 Pryout Strength

$$V_{cp} = k_{cp} \left[\left(\frac{A_{Nc}}{A_{Nc0}} \right) \psi_{ed,N} \psi_{c,N} \psi_{cp,N} N_b \right] \quad \text{ACI 318-14 Eq. (17.5.3.1a)}$$

$$\phi V_{cp} \geq V_{ua} \quad \text{ACI 318-14 Table 17.3.1.1}$$

$$A_{Nc} \text{ see ACI 318-14, Section 17.4.2.1, Fig. R 17.4.2.1(b)}$$

$$A_{Nc0} = 9 h_{ef}^2 \quad \text{ACI 318-14 Eq. (17.4.2.1c)}$$

$$\psi_{ec,N} = \left(\frac{1}{1 + \frac{2 e_N}{3 h_{ef}}} \right) \leq 1.0 \quad \text{ACI 318-14 Eq. (17.4.2.4)}$$

$$\psi_{ed,N} = 0.7 + 0.3 \left(\frac{c_{a,min}}{1.5 h_{ef}} \right) \leq 1.0 \quad \text{ACI 318-14 Eq. (17.4.2.5b)}$$

$$\psi_{cp,N} = \text{MAX} \left(\frac{c_{a,min}}{c_{ac}}, \frac{1.5 h_{ef}}{c_{ac}} \right) \leq 1.0 \quad \text{ACI 318-14 Eq. (17.4.2.7b)}$$

$$N_b = k_c \lambda_a \sqrt{f'_c} h_{ef}^{1.5} \quad \text{ACI 318-14 Eq. (17.4.2.2a)}$$

Variables

k_{cp}	h_{ef} [in.]	$e_{c1,N}$ [in.]	$e_{c2,N}$ [in.]	$c_{a,min}$ [in.]
2	2.750	0.000	0.000	10.000

$\psi_{c,N}$	c_{ac} [in.]	k_c	λ_a	f'_c [psi]
1.000	4.125	17	1.000	2500

Calculations

A_{Nc} [in. ²]	A_{Nc0} [in. ²]	$\psi_{ec1,N}$	$\psi_{ec2,N}$	$\psi_{ed,N}$	$\psi_{cp,N}$	N_b [lb]
68.06	68.06	1.000	1.000	1.000	1.000	3876

Results

V_{cp} [lb]	$\phi_{concrete}$	ϕV_{cp} [lb]	V_{ua} [lb]
7753	0.700	5427	113

www.hilti.us

Company: CAE PIPING
 Specifier: SAM SALISSEN
 Address:
 Phone | Fax: |
 E-Mail:

Page: 5
 Project: SIDE ANCHOR BOLTS
 Sub-Project | Pos. No.:
 Date: 6/24/2019

4.3 Concrete edge failure in direction x+

$$V_{cb} = \left(\frac{A_{Vc}}{A_{Vc0}} \right) \psi_{ed,V} \psi_{c,v} \psi_{h,v} \psi_{parallel,V} V_b \quad \text{ACI 318-14 Eq. (17.5.2.1a)}$$

$$\phi V_{cb} \geq V_{ua} \quad \text{ACI 318-14 Table 17.3.1.1}$$

A_{Vc} see ACI 318-14, Section 17.5.2.1, Fig. R 17.5.2.1(b)

$$A_{Vc0} = 4.5 c_{a1}^2 \quad \text{ACI 318-14 Eq. (17.5.2.1c)}$$

$$\psi_{ec,V} = \left(\frac{1}{1 + \frac{2e_v}{3c_{a1}}} \right) \leq 1.0 \quad \text{ACI 318-14 Eq. (17.5.2.5)}$$

$$\psi_{ed,V} = 0.7 + 0.3 \left(\frac{c_{a2}}{1.5c_{a1}} \right) \leq 1.0 \quad \text{ACI 318-14 Eq. (17.5.2.6b)}$$

$$\psi_{h,v} = \sqrt{\frac{1.5c_{a1}}{h_a}} \geq 1.0 \quad \text{ACI 318-14 Eq. (17.5.2.8)}$$

$$V_b = \left(7 \left(\frac{l_e}{d_a} \right)^{0.2} \sqrt{d_a} \right) \lambda_a \sqrt{f_c} c_{a1}^{1.5} \quad \text{ACI 318-14 Eq. (17.5.2.2a)}$$

Variables

c_{a1} [in.]	c_{a2} [in.]	e_{cV} [in.]	$\psi_{c,v}$	h_a [in.]
6.667	10.000	0.000	1.000	5.000

l_e [in.]	λ_a	d_a [in.]	f_c [psi]	$\psi_{parallel,V}$
2.750	1.000	0.375	2500	1.000

Calculations

A_{Vc} [in. ²]	A_{Vc0} [in. ²]	$\psi_{ec,v}$	$\psi_{ed,v}$	$\psi_{h,v}$	V_b [lb]
100.00	200.00	1.000	1.000	1.414	5495

Results

V_{cb} [lb]	$\phi_{concrete}$	ϕV_{cb} [lb]	V_{ua} [lb]
3886	0.700	2720	113

5 Combined tension and shear loads

β_N	β_V	ζ	Utilization $\beta_{N,V}$ [%]	Status
0.585	0.048	5/3	42	OK

$$\beta_{NV} = \beta_N^\zeta + \beta_V^\zeta \leq 1$$

6 Warnings

- Load re-distributions on the anchors due to elastic deformations of the anchor plate are not considered. The anchor plate is assumed to be sufficiently stiff, in order not to be deformed when subjected to the loading! Input data and results must be checked for agreement with the existing conditions and for plausibility!
- Condition A applies when supplementary reinforcement is used. The Φ factor is increased for non-steel Design Strengths except Pullout Strength and Pryout strength. Condition B applies when supplementary reinforcement is not used and for Pullout Strength and Pryout Strength. Refer to your local standard.
- Refer to the manufacturer's product literature for cleaning and installation instructions.
- Checking the transfer of loads into the base material and the shear resistance are required in accordance with ACI 318 or the relevant standard!
- Hilti post-installed anchors shall be installed in accordance with the Hilti Manufacturer's Printed Installation Instructions (MPII). Reference ACI 318-14, Section 17.8.1.

Fastening meets the design criteria!

www.hilti.us

Company: CAE PIPING
Specifier: SAM SALISSEN
Address:
Phone | Fax: |
E-Mail:

Page: 6
Project: SIDE ANCHOR BOLTS
Sub-Project | Pos. No.:
Date: 6/24/2019

7 Installation data

Anchor plate, steel: -
Profile: -
Hole diameter in the fixture: -
Plate thickness (input): -
Recommended plate thickness: -
Drilling method: Hammer drilled
Cleaning: Manual cleaning of the drilled hole according to instructions for use is required.

Anchor type and diameter: Kwik Bolt TZ - CS 3/8 (2 3/4)
Installation torque: 300.000 in.lb
Hole diameter in the base material: 0.375 in.
Hole depth in the base material: 3.375 in.
Minimum thickness of the base material: 5.000 in.

7.1 Recommended accessories

Drilling	Cleaning	Setting
<ul style="list-style-type: none">Suitable Rotary HammerProperly sized drill bit	<ul style="list-style-type: none">Manual blow-out pump	<ul style="list-style-type: none">Torque wrenchHammer

Coordinates Anchor in.

Anchor	x	y	C-x	C+x	C-y	C+y
1	0.000	0.000	10.000	10.000	10.000	10.000

8 Remarks; Your Cooperation Duties

- Any and all information and data contained in the Software concern solely the use of Hilti products and are based on the principles, formulas and security regulations in accordance with Hilti's technical directions and operating, mounting and assembly instructions, etc., that must be strictly complied with by the user. All figures contained therein are average figures, and therefore use-specific tests are to be conducted prior to using the relevant Hilti product. The results of the calculations carried out by means of the Software are based essentially on the data you put in. Therefore, you bear the sole responsibility for the absence of errors, the completeness and the relevance of the data to be put in by you. Moreover, you bear sole responsibility for having the results of the calculation checked and cleared by an expert, particularly with regard to compliance with applicable norms and permits, prior to using them for your specific facility. The Software serves only as an aid to interpret norms and permits without any guarantee as to the absence of errors, the correctness and the relevance of the results or suitability for a specific application.
- You must take all necessary and reasonable steps to prevent or limit damage caused by the Software. In particular, you must arrange for the regular backup of programs and data and, if applicable, carry out the updates of the Software offered by Hilti on a regular basis. If you do not use the AutoUpdate function of the Software, you must ensure that you are using the current and thus up-to-date version of the Software in each case by carrying out manual updates via the Hilti Website. Hilti will not be liable for consequences, such as the recovery of lost or damaged data or programs, arising from a culpable breach of duty by you.