



WEIL-McLAIN

Ultra Oil

Oil-Fired Water Boiler

Addendum

This Addendum needs to be used in conjunction with Boiler Manual P/N 550-141-986/1005 - Ultra Oil -

NOTICE

Indicates special instructions on installation, operation or maintenance that are important but not related to personal injury or property damage.

NOTICE

Changes to text. The following information replaces the referenced text on page 10 of the Ultra Oil Boiler Manual.

Combustion chamber floor blanket —

All Direct Vent and UO-3, 0.8 GPH firing rate

Place the **ceramic fiber floor blanket** on the floor of the combustion chamber. The blanket and instructions are supplied in the UO-3 low firing rate kit for the 0.8 GPH boiler or supplied with the Beckett burner for direct vent. See page 33 for location.

Check chamber and burner door

2. All Direct Vent and UO-3, 0.8 GPH firing rate — Check for secure placement of combustion chamber floor blanket.

NOTICE

For page 32, the following text change:

Item 19, Description is “All Direct Vent and UO-3, 0.8 GPH firing rate” 591-221-287

NOTICE

For page 36, make the following replacements:

Item 13, Description is “Cover Control Bracket” 595-000-010 (Replaces 550-404-306)



As an ENERGY STAR Partner, Weil-McLain has determined that this product meets the ENERGY STAR guidelines for energy efficiency

Weil-McLain
500 Blaine Street
Michigan City, IN 46360-2388
<http://www.weil-mclain.com>

550-142-050/0508