

### SCHEMATIC WIRING DIAGRAM



### LADDER WIRING DIAGRAM



LOW VOLTAGE -----

#### NOTES:

- ALL WIRING MUST BE INSTALLED IM ACCORDANCE WITH:

  A. U.S.A. NATIONAL ELECTRICAL CODE AND ANY OTHER NATIONAL. STATE, OR LOCAL CODE REQUIREMENTS MAYING JURISDICTION.

  B. CAMADA C.S.A. C22.1 CAMADIAN ELECTRICAL CODE PART 1 AND ANY OTHER NATIONAL, PROVINCIAL, NO I LOCAL CODE REQUIREMENTS MAYING JURISDICTION.
- ALL SAFETY CIRCUIT WIRING MUST BE: A. U.S.A. N.E.C. CLASS 1. B. GANADA C.S.A. C22.1 C.E.C. PART 1. IF ORIGINAL ROLLOUT SWITCH WIRE AS SUPPLIED WITH THE APPLIANCE MUST BE REPLACED TYPE 200°C WIRE OR ITS COLVINACIE MUST BE USED. IF OTHER ORIGINAL WIRE AS SUPPLIED WITH THE APPLIANCE MUST BE REPLACED, TYPE 90°C OR TIS COLVINALIMI MUST BE USED.
- REFER TO CONTROL COMPONENT INSTRUCTIONS PACKED WITH BOILER FOR APPLICATION INFO
- ADJUST HICH LIMIT TO MAXIMUM SETTING. OPERATING LIMIT SHOULD BE ADJUSTED TO MINIMUM 2 PSI BELOW RIGH LIMIT TO ELIMINATE HUISANCE PILOT OUTAGE.

NOTICE - ALL CONTACTS SHOWN WITHOUT POWER APPLIED - OFF SHELF CONDITION.


Wiring Diagram for EG
• Standing Pilot, Millivott
• Steam without Tankless

LIED


**WEIL-McLAIN** A Division of The Morley Com-Michigan City, Indiana 46360

PART NUMBER 550-224-057/1290WM

## SCHEMATIC WIRING DIAGRAM



# LADDER WIRING DIAGRAM



LOW VOLTAGE -----

#### HOTES:

- - ALL WIRING MUST BE INSTALLED IN ACCORDANCE WITH:

    A. U.S.A. NATIONAL ELECTRICAL CODE AND ANY OTHER NATIONAL, STATE, OR LOCAL CODE REQUIRELENTS MAYING JURISDICTION.

    B. CANADA C.S.A. C22.1 CANADAN ELECTRICAL CODE PART 1 AND ANY OTHER NATIONAL, PROVINCIAL OR LOCAL CODE REQUIRELENTS MAYING JURISDICTION.
- ALL SAFETY CIRCUIT WIRING MUST BE:
  A. U.S.A. N.E.C. CLASS 1.
  B. CANADA C.S.A. C22.1 C.E.C. PART 1.
- IF ORIGINAL ROLLOUT SWITCH WIRE AS SUPPLIED WITH THE APPLIANCE MUST BE REPLACED, TYPE 200°C WIRE OR ITS COUNALENT MUST BE USED. IF OTHER ORIGINAL WIRE AS SUPPLIED WITH THE APPLIANCE MUST BE REPLACED, TYPE 90°C OR ITS EQUIVALENT MUST BE USED. REFER TO CONTROL COMPONENT INSTRUCTIONS PACKED WITH BOILER FOR APPLICATION INFORMATION.
- NOTICE ALL CONTACTS SHOWN WITHOUT POWER APPLIED OFF SHELF CONDITION.

Wiring Diagram for EG
• Standing Pilot, Millivoit
• Gravity Hot Water without Tankless

## **WEIL-McLAIN**

Division ision of The Mariey Compony Michigan City, Indiana 46360

PART NUMBER \$50-224-051/1290WM