

- 3. IF ORIGINAL ROLLOUT TFE WIRE AS SUPPLIED WITH THE APPLIANCE MUST BE REPLACED. TYPE 200°C WIRE OR ITS EQUIVALENT MUST BE USED. IF OTHER ORIGINAL WIRE AS SUPPLIED WITH THE APPLIANCE MUST BE REPLACED, TYPE 105℃ OR ITS EQUIVALENT MUST BE USED.
- 4. REFER TO CONTROL COMPONENT INSTRUCTIONS PACKED WITH BOILER FOR APPLICATION INFORMATION.
- 5. THERMOSTAT SET ANTICIPATOR TO MATCH AMPERE DRAW OF GAS VALVE

PLUS VENT DAMPER (IF USED). EMCS - FOR EMCS CONNECTION IN PLACE OF THERMOSTAT, REFER TO EMCS INSTALLATION/OPERATING MANUAL.

- 6. L.W.C.O., ADDITIONAL HIGH LIMIT, ETC., WIRED IN SERIES.
- I DENOTES FIELD INSTALLED CHASSIS GROUND.
- 8. OPERATING CONTROL REQUIRED WITH TANKLESS HEATER.
- 9. PILOT LEADWIRES ARE NOT FIELD REPLACEABLE, REPLACE PILOT ASSEMBLY IF NECESSARY.
- EGH
 - 85 thru 125
- Intermittent Pilot Natural Gas

CABLE

TO

DAMPER

- · Steam, With or Without Tankless
- Probe-Type Low Water Cut Off



LADDER WIRING DIAGRAM

OPERATING

CONTROL

(NOTE 8)

LIMIT

CONTROL

UNIVERSAL SPARK

IGNITION CONTROL

ΜV

PV

24V

SENSOR

IGNITOR

MV/PV

-120 V.A.C.

PRIMARY

24 V.A.C.

LOW WATER **CUT-OFF**

THERMOSTAT

(NOTE 5)

ADDITIONAL

LIMITS

(NOTE 6)

ROBERTSHAW

GAS VALVE

TR

GND

(BURNER)

24V (GND)

SENSE

□ OR EMCS

FUSE

(3)

6

 \bigcirc

DAMPER

CONNECTOR

3

(5)

4

2

6

 \odot

LOW VOLTAGE FIELD

HIGH VOLTAGE FIELD LOW VOLTAGE FACTORY

IGNITION CABLE

HIGH VOLTAGE FACTORY

SERVICE SWITCH

(BY OTHERS)

EQUIPMENT

GROUND

(NOTE 7)

WEIL-McLAIN

A United Dominion Company Weil-McLain • 500 Blaine St. • Michigan City, IN 46360-2388

PART NUMBER 550-223-818/0196WM