

GOLD GV Water boiler — Series 3

Venting Supplement

Saf-T Vent® — 4" venting

Special gas vent system vent and combustion air supplement for 4" diameter venting



NOTICE

WARNING

Heat-Fab, Inc. **Saf-T Vent**[®] AL29-4C[®] Stainless Steel Special Gas Vent System may be used in new installations of GV-3 through GV-6 boilers.



Hazard definitions

The following terms are used throughout this Venting Supplement to bring attention to the presence of hazards of various risk levels or to important information concerning the life of the product.

- **DANGER** Indicates presence of hazards that will cause severe personal injury, death or substantial property damage.
- **WARNING** Indicates presence of hazards that can cause severe personal injury, death or substantial property damage.
- **CAUTION** Indicates presence of hazards that will or can cause minor personal injury or property damage.

Indicates special instructions on installation, operation or maintenance that are important but not related to personal injury or property damage.

To the installer:

This Venting Supplement must only be used by a qualified installer/service technician. Read these instructions completely before beginning the installation. Failure to follow these instructions in proper order can cause severe personal injury, death or substantial property damage.

To install a new vent system follow instructions in:

- This Venting Supplement.
- GV Boilers Vent/Air Intake Termination Assembly Instructions, if using Weil-McLain Vent/Air Intake Termination Kit.
- Saf-T Vent[®] manufacturer's instructions supplied with vent material.

For installations above 5,500 feet use only direct vent (ducted combustion air) when sidewall venting. All of the vertical (through-roof or throughunused-chimney) methods in this Venting Supplement are acceptable. Can result in severe personal injury, death or substantial property damage if ignored.

NOTICE

WARNING

4" Diameter vent lengths are determined using standard 3" diameter GV starters and 24" or less of 3" diameter vent termination length.



Combustion air supply

Special note

Refer to GV Series 3 Boiler Manual for sizing free area of combustion/ventilation air openings.

All boilers experience some condensation in section assembly during start-up. Unlike most conventional boilers, condensation is minimized in the GV Series 3 Boiler by a built-in mixing system, maintaining boiler return water temperature above 130 °F, during steady state operation.

Flue gas condensate is slightly acidic. In most cases pH level is not harmful to vents or drains. When combustion air is contaminated by vapors from products and areas, listed in Table 1 below, condensate acidic levels increase. Higher acidic levels attack many materials, including stainless steel commonly used in high efficiency systems.

You may choose to use outside combustion air for any of the following reasons:

- Installation is in an area containing contaminants listed in Table 1 below, which will • induce acidic contamination.
- You want to reduce infiltration into your home through openings around windows and doors.

Table 1 Corrosive contaminants

Products to avoid	Areas likely to have contaminants				
Spray cans containing chloro/fluorocarbons	Dry cleaning/laundry areas and establishments				
Permanent wave solutions	Swimming pools				
Chlorinated waxes/cleaners	Metal fabrication plants				
Chlorine-based swimming pool chemicals	Beauty shops				
Calcium chloride used for thawing	Refrigeration repair shops				
Sodium chloride used for water softening	Photo processing plants				
Refrigerant leaks	Auto body shops				
Paint or varnish removers	Plastic manufacturing plants				
Hydrochloric acid/muriatic acid	Furniture refinishing areas and establishments				
Cements and glues	New building construction				
Antistatic fabric softeners used in clothes dryers	Remodeling areas				
Chlorine-type bleaches, detergents, and clean- ing solvents found in household laundry rooms	Garages with workshops				
Adhesives used to fasten building products and other similar products					

workshops



To prevent potential of severe personal injury or death, check for areas and products listed above before installing boiler. If found:

- remove products permanently OR —
- provide outside combustion air

UM

Vent termination

Venting method definitions

Direct vent — Uses outside combustion air with combustion air connector piping sealed at all joints and seams. Also known as "sealed combustion".

Non-Direct vent — Uses inside combustion air with no combustion air connector piping.

Properly locate vent termination



Follow instructions on this page when determining vent location to avoid possibility of severe personal injury, death or substantial property damage.

- 1. When using direct vent method Refer to separate instructions packed with Weil-McLain direct vent termination kit and vent pipe manufacturer's instructions for additional locations.
- 2. For location of non-direct vent vertical termination, see vent pipe manufacturer's instructions.
- 3. Gases will form white plume in winter. Plume could obstruct window view.
- 4. Prevailing winds could cause freezing of condensate and water/ice buildup on building, plants or roof.
- 5. Locate or guard vent to prevent accidental contact by people or pets.
- 6. Do not terminate vent in window well, stairwell, alcove, courtyard, or other recessed areas.
- 7. Non-Direct vent installations only Vent must terminate more than 4 feet below or to side of all doors or windows. See Figure 1.
- 8. Vent must terminate more than 1 foot above grade or

anticipated snow line. In addition, vent termination must be at least 7 feet above public walkway and 3 feet above any forced air intake within 10 feet. Stay well away from trees, shrubs, and decorative items. Site conditions may dictate greater clearances. See Figure 1.

- 9. Vent must terminate at least 4 feet horizontally, and in no case above or below, unless a 4 foot horizontal distance is maintained, from electric meters, gas meters, regulators, relief valves, and other equipment.
- 10. Locate or guard vent to prevent condensate from damaging exterior finishes.
- 11. Do not extend exposed vent pipe outside of building. Condensate could freeze and block vent pipe.
- 12. Vent must terminate at least 6 feet away from adjacent walls.
- 13. Do not terminate vent closer than 5 feet below roof overhang.
- 14. Do not terminate vent above any door or window. Condensate can freeze, causing ice formations.
- 15. Do not use existing chimney as raceway if another appliance or fireplace is vented into or through chimney.
- 16. Do not connect:
 - Any other appliance to vent pipe.
- Multiple boilers to a common vent pipe.
- 17. Do not wrap or insulate vent pipe and fittings.
- 18. Canadian installations See CAN/CGA B149.1 or B149.2 Installation Code.
- 19. WARNING A gas vent extending through an exterior wall shall not terminate adjacent to the wall or below building extensions such as eaves, parapets, balconies or decks. Failure to comply could result in severe personal injury, death or substantial property damage.







Installation

Table 2

Parts list

Pre-installation planning

- 1. Follow national, state, local or provincial codes or regulations when venting GV boiler.
- 2. Choose vent method from those shown on page 5.
- 3. Select vent run components from Table 2. Table 3 states maximum vent run lengths and number of elbows. Do not exceed data in Table 3. See Figure 2 for slightly reduced boiler output.
- 4. If installing with direct vent method, use same maximum run length and number of elbows from

step 2. Vent and combustion air connector piping configurations must match. Use suitable 3" material for combustion air connector piping, such as:

- Dryer vent
- Galvanized steel
- PVC (3" I.D.)
- 5. Refer to vent termination WARNING, item 19 on page 3.

Description	Weil-McLain	Heat-Fab, Inc. Part Number		
	Part Number	4" dia. (Note 2 & 3)		
GV starter tee	699-999-025	73WMSTXL		
GV termination coupling	699-999-001	73WMTERM		
45 [°] elbow		7411GC		
90° elbow		7414GCTR		
6" pipe		7401GC		
12" pipe	A	7402GC		
18" pipe	Available through	7404GC		
18" slip connector (Note 1)	local	7424GC		
24" pipe	supply	7405GC		
37 ½" pipe	house.	7407GC		
49 ½" pipe		7408GC		
Horizontal support		7423GC		
3 Inch diameter to 4 inch diameter transition		7374GC		
4 Inch diameter to 3 inch diameter transition		7473RDCR		
Weil-McLain Vent/Air Intake Termination Kit	382-200-430			

Notes

1. Use to adjust for non-standard pipe lengths and before termination coupling to terminate run

The GV boiler vent connection is always 3 inch diameter, requiring a 3" to 4" vent adapter when 4" vent is used.

3. Through-Roof or Unused-Chimney Termination Kit not certified with 4" diameter vent.

Table 3Vent and combustion air connector piping
lengths and number of elbows

	Total number of elbows										
	0	2	3	4	5	6	7	8			
Maximum vent length (feet)	150	130	120	110	100	90	80	70			
Note: 4" Diameter vent lengths are determined using standard 3" diameter GV starters and 24" or less of 3" diameter vent termination.											

Figure 2 Boiler output





WARNING

For altitudes more than 5,500 feet above sea level — **Do not** use non-direct vent through sidewall methods as shown in **Figures 4** and **5** below. Can cause severe personal injury, death or substantial property damage if ignored.

Select vent method:





Installation — assembly

Connect vent starter tee to boiler

Follow the instructions in the GV Series 3 Boiler Manual section **IIb** to connect the vent starter tee to the boiler.

Construct vent and optional combustion air run

WARNING Follow vent pipe manufacturer's instructions for sealing the vent. Vent and combustion air connector piping must be sealed gas-tight to prevent possibility of flue gas spillage and carbon monoxide emissions, resulting in severe personal injury or death.

- 1. Follow Saf-T Vent[®] manufacturer's instructions to construct vent run and for methods of supporting vent runs.
 - Clean joints before sealing. See vent pipe manufacturer's instructions to clean joints.
 - Use their specified sealant (maximum 250 °F flue temperature). Do not use screws.
 - Do not mix types or manufacturers of vent materials.
 - Maintain minimum one-inch clearance from combustible materials to vent pipe; 0" clearance for noncombustible materials.
 - Install vent pipe with seams on top of vent runs. Refer to Figures 3 through 6 on page 5 when installing increasers or reducers.
 - If needed, use slip connector to adjust for nonstandard pipe length. See vent pipe manufacturer's instructions for use.
- 2. If installing with direct vent through sidewall method, use instructions provided with Weil-McLain Vent/Air Intake Termination Kit. See Figure 3, page 5.

Connect vent run to termination

Venting through sidewall

- 1. If using Weil-McLain Vent/Air Intake Termination Kit, see instructions provided in that kit. Applies to direct (Figure 3, page 5) or non-direct vent (Figure 4, page 5) method.
- 2. If using non-direct method with termination coupling only, see Figures 7 and 8.
 - Do not seal slip connector to inside or outside plate.
 - If passing through noncombustible wall, provide hole diameter large enough to insert the slip connector through. Sleeve and spacers are not required.
- 3. Maintain minimum one-inch clearance from combustible materials to vent pipe; 0" clearance for noncombustible materials.
- 4. Refer to vent termination WARNING, item 19 on page 3.

Venting through roof

- 1. Non-Direct vent method (only through the roof, not through chimney):
 - Vent pipe must extend through roof flashing, jacket or thimble. See Figure 9.
 - Vent may pass through floor, inside wall or concealed space when installed according to vent pipe manufacturer's instructions.
- 2. Maintain minimum one-inch clearance from combustible materials to vent pipe.





Installation — assembly continued

Finish the vent installation

Installing condensate tubing

1. See **Figure 10** to install condensate tubing (provided by others). Use condensate pump if floor drain is higher than condensate drain on boiler.

If required:

- use a low-profile pump OR —
- set boiler on foundation (see GV Series 3 Boiler Manual) to allow gravity flow to pump.
- 2. Size pump in gal/hr (boiler model):
 - 0.78 (GV-3)
 - 1.17 (GV-4)
 - 1.56 (GV-5)
 - 1.95 (GV-6)

Refer to pump manufacturer's instructions. Drain to a non-freezing area.

Figure 10

Installation of condensate tubing



If vent pipe or combustion air pipe must be reassembled

When vent pipe or combustion air pipe is disconnected for any reason, it must be reassembled and resealed according to this Venting Supplement, the direct vent termination kit instructions and the vent pipe manufacturer's instructions.



Sealant recommended by vent pipe manufacturer must be used as indicated in their instructions. Vent and combustion air connector piping must be sealed gas-tight to prevent possibility of flue gas spillage and carbon monoxide emissions, resulting in severe personal injury or death.



Weil-McLain 500 Blaine Street Michigan City, IN 46360-2388 http://www.weil-mclain.com