
TO: All Weil-McLain Distributors and Agents
FROM: Tony Curran, V.P. of Sales
SUBJECT: **REMINDER** – IMPORTANT PRODUCT SAFETY NEWS

Potential Safety Issue

CGS 3, 4, 5 & 6 Section Boilers and CGI 3, 5 & 6 Section Boilers

Attached are two previously released Weil-McLain Marketing Bulletins (MB-0802, MB-0808), detailing potential safety issues. Weil-McLain encourages you to review this information and contact contractors that previously purchased these boilers to implement the necessary corrections.

Important Product Safety Notice – Action Required

Effikal Automatic Gas Vent Damper

In September 2008, Effikal, LLC announced a voluntary Wholesaler Distributor Replacement Program for certain Automatic Gas Vent Dampers manufactured between July 1, 2007 and March 1, 2008 due to safety and quality issues. **Effikal has recently expanded the Weil-McLain serial number range.** Date Codes remain unchanged. Advise your contractors of this change and have them implement the necessary corrections. Attached is a copy of the updated CPSC Bulletin. For the complete bulletin, visit the CPSC website @ www.cpsc.com. If you have any questions, contact the Effikal Hotline at 866-790-3739.

Enclosures: W-M MB-0802
W-M MB-0808
CPSC Bulletin