



# Burner Manual Supplement

for Weil-McLain Boilers

## GOLD Oil

### Nozzle selections and burner settings

1. See Table 1 for recommended oil nozzle selections and initial burner settings. Follow Burner Manual and Boiler Manual for installation of nozzle if not supplied with boiler/burner.
2. Where the table calls for an oil pump pressure other than as-shipped, adjust the pump pressure to the setting shown, following pump manufacturer's instructions.

### Special requirements

1. Parts  
 Primary control ..... 60200.....Carlin 60200-00, 10 sec pre/post  
 Fuel unit..... 98750.....Suntec A2VA-3006  
 Oil valve.....In pump  
 Flange.....Welded, included with air tube  
 Air tube/flange..... 84863=EZ-1 .....5" air tube, 3 1/8" UTL, 1 1/2° pitch  
 Air tube/flange..... 84871=EZ-2 .....5" air tube, 3 1/8" UTL, 1 1/2° pitch  
 Combustion head..... 77958.....5" no heater
2. Draft requirements  
 Draft over fire – 0.01 to –0.02 inches w.c.

#### ⚠ WARNING

Installer/servicer — Except where specifically stated otherwise, this Supplement must be used only by a **qualified service technician**. Follow all guidelines in the Burner Manual and Boiler Manual. Failure to comply with this or other requirements in this manual could result in severe personal injury, death or substantial property damage.

Table 1 Burner specifications and settings for Weil-McLain GOLD Oil Boilers

Boiler Model	Input	Burner Model	Nozzle Specifications			Oil Pump Pressure (PSIG)	Head Bar	Air Band Setting
			Size	Type	Manufacturer			
G0-2	0.70	EZ-1HP	0.60	70B	Delavan	140	0.60/0.65	0.50
G0-3	0.70	EZ-1HP	0.60	70B	Delavan	140	0.60/0.65	0.50
G0-3	0.95*	EZ-1HP	0.75	60B	Delavan	160	0.75	0.75
G0-4	1.00	EZ-1HP	0.85	70B	Delavan	140	0.85/1.00	0.85
G0-4	1.20*	EZ-1HP	1.00	60B	Delavan	145	0.85/1.00	1.00
G0-5	1.20	EZ-1HP	1.00	70B	Delavan	140	0.85/1.00	1.10
G0-5	1.45*	EZ-1HP	1.20	60B	Delavan	150	1.10/1.25	1.40
G0-6	1.40	EZ-1HP	1.20	60B	Delavan	140	1.10/1.25	1.35
G0-6	1.75*	EZ-2HP	1.50	60AB	Danfoss	140	1.50	1.45

\* Factory supplied setting.